

<ul style="list-style-type: none"> ○ Potable Water tests ○ FoodSafe ○ WaterSafe ○ Gas Inspection (propane) 		
<p>CAMP ORIENTATION</p> <ul style="list-style-type: none"> ○ Young or New Worker Orientation – OH&S Reg 3.22 to 3.25 ○ Workplace conduct for residence ○ ETS - Environmental Tobacco Smoke ○ Hazardous Wildlife precautions and procedures ○ Drug and Alcohol Policy ○ Firearm Policy and Storage ○ Bio-hazards and Washing expectations ○ Waste disposal Procedures ○ Emergency & Evacuation Procedures (Posted Fire Safety Plan must be posted in each room and emergency procedures near main entrances) ○ Working Alone 	<p>3.22 3.25</p> <p>4.21</p>	<p><input type="checkbox"/></p> <p><input type="checkbox"/></p>
<p>GENERAL COMPLIANCE issues</p> <ul style="list-style-type: none"> ○ Illumination on all outside entrances ○ Illuminated exit signs on all exit doors ○ Fuel storage as on permit from BC Fire Commission; (safe storage). Multi-fuel skids to meet the requirements of BCFC 4.3.2.3 and CSA B-149.2. (20 feet distance between Diesel and Propane, 25 feet distance between Gasoline and Propane and stored 50 feet distance to any building). ○ Fire separation walls – 30 minute fire rating between bedrooms (1/2" drywall), 45 minute fire rating between hallways (5/8" drywall) ○ Fire rated vents on furnace, ducts and doors ○ Burn Pan under water heaters ○ Fuel shut off valve and wrench (if needed) near gas fired appliances ○ All exit doors with quick release handles, door openings not blocked or exposed to a hazard; safe access 	<p>5.26 5.36(1)(a)</p> <p>4.32</p>	<p><input type="checkbox"/></p> <p><input type="checkbox"/></p>

<ul style="list-style-type: none"> ○ Automatic door closures (ULC rated) on Fire Separations doors and suite doors (20 minute fire rating, 45 minute rating for all other Fire Separation doors) ○ Female rooms, wash facilities and toilets have a lockable door ○ Basic First-aid ○ Written agreement between employers on First-aid coverage for their workers staying in camp ○ Safe Premises ○ Safe Machinery and Equipment ○ Emergency Preparedness ○ Emergency Response Plan, Evacuation Plan ○ Violence in the Workplace ○ Exposure Control Plan and Procedures – OH&S Reg 5.54 for Air contaminants, Bio-hazards(sharps), Hygiene and infectious diseases ○ Lock-out or De-energization of equipment or machinery ○ Fall Protection for Roof work or work over 10 feet ○ Electrical generator properly grounded ○ Protection of compressed Gas ○ Garbage and Waste storage must be 10 meters from any building ○ Fuel storage is compliant with the Fire Permit. All fuel Storage vessels grounded, includes Trailers with fuel (such as Propane tanks) attached ○ Carbon Monoxide detectors required near all carbon producing appliances (110 volt hard wired) 	<p style="text-align: center;">3.16</p> <p style="text-align: center;">4.1</p> <p style="text-align: center;">4.3</p> <p style="text-align: center;">4.13(1)</p> <p style="text-align: center;">4.2.7</p> <p style="text-align: center;">5.54</p> <p style="text-align: center;">10.2</p> <p style="text-align: center;">11.3</p> <p style="text-align: center;">5.36</p>	<p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p> <p style="text-align: center;"><input type="checkbox"/></p>
<p>COMPLEX - 6 rooms or more</p> <ul style="list-style-type: none"> ○ Fire Detection System - 110 volt hard wired system ○ All sleeping units – heat detectors wired into central alarm, smoke alarms not wired into central alarm system (after Nov 2006 new code does not require heat detectors; now called Fire Detectors. But prior installations must retain and maintain heat detectors) ○ Fire System detection panel ○ Pull stations in hall ways ○ Fire detectors in mechanical areas; i.e. over furnaces, hot water tanks ○ Smoke detectors in hall ways and exit stairways. 		

<ul style="list-style-type: none"> ○ Fire Detectors required in all enclosures (janitor closets, storage, service laundry rooms) ○ Water hose system for fire-fighting purposes for camps with more than 30 beds 		
<p>SINGLE TRAILER UNITS</p> <ul style="list-style-type: none"> ○ 110 volt hard wired smoke alarm in each room and all interconnected ○ One fire extinguisher on outside of unit mounted mid-point ○ Minimum 10 meters of separation between units, or 1.22 meters end to end with a 45minute fire rating on the end walls ○ Fire Detectors required in all enclosures (janitor closets, storage, service laundry rooms) 		
<p>OTHER JURISDICTIONS</p> <ul style="list-style-type: none"> ○ British Columbia Objective Based Building Code ○ Health Code – food, sanitation, potable water ○ British Columbia Objective Based Fire Code (including reference documents, NFPA (National Fire Publication Association), ULC, CSA) ○ Labour Code ○ Human Rights Code and Law ○ Federal Firearms Law ○ Canadian Electrical Code Part One (Ground fault Circuit Interrupters) 		